



# Request For Quotation

**Description** : RFQ-002053 - Earthing Pits / Earthing Pits  
**Date of Issue** : 1 Aug 2024  
**Date of Submission of Quotation** : 5 Aug 2024 11:00:00 AM  
**Place of Delivery** : IBA Karachi, Main Campus, Karachi  
**Contact Person & Telephone** : Purchase Department IBA Main Campus, University Road, Karachi.  
 03122669895  
 Extension : 2150

Sr#	Description	Quantity + UOM
1	; ; ; ; Earthing Pits Earthing system for A.C., D.C. and L.A. less than 1 Ohm with copper cladded 3 meter long minimum 16mm dia rod, minimum depth of earth pit should be 35 feet including copper test bar, earthing chemical and inspection pit. Minimum 16mm Bare conductor wire and minimum 1" UPVC pipe for water drain with heavy duty earth pit cover. Earth test report to be submitted by vendor to client. IBA Main Campus Price including SST.	4.00 EACH

**Terms & Conditions :**

1. Material of this order is subject to final inspection at the time of delivery.
2. We reserve the right to cancel any or all the above items if material is not in accordance with our specification or if the delivery is delayed.
3. Payment will be made through crossed cheque after the receipt of the Invoice/Bill & delivery of above item(s).
4. General Sales Tax will be paid on applicable items only.
5. Liquidity damage at the rate of 2% per month on actual will be imposed on delayed delivery.
6. The rate I item cost is final and no change what so ever will be accepted.
7. Government tax(es), levi(es) and charge(s) will be charged at actual as per SRO.
8. Competent Authority reserves the right to change/ alter I remove any item or article or reduce I enhance quantity without assigning any reason.
9. Invoice/Bill to be submitted to Purchase Department.
10. Advance Payment subject to Bank Guarantee.
11. All Government taxes (including Income tax and stamp duty), levies and charges will be charged as per applicable rates I denomination of Purchase Order.
12. Stamp Duty 0.35% for Goods against total value of Purchase Order will be levied accordingly.