

## **Qambar Zaidi / Senior Executive Purchase**

---

**From:** Mansoor Ali / Manager IT  
**Sent:** Wednesday, June 16, 2021 12:30 PM  
**To:** Qambar Zaidi / Senior Executive Purchase  
**Cc:** Syed Muhammad Wajeesh Zaidi / Acting Head of ICT  
**Subject:** FW: haier 8 ton Hpu 96

**Importance:** High

Dear Mr. Qamber,

Please note that the delivery model does not meet EER – Requirement. Please replace it with the required EER model.

Regards,  
Mansoor Ali

---

**From:** Syed Muhammad Wajeesh Zaidi / Acting Head of ICT <smwzaidi@iba.edu.pk>  
**Sent:** Wednesday, May 19, 2021 3:01 PM  
**To:** Mansoor Ali / Manager IT <mali@iba.edu.pk>  
**Subject:** FW: haier 8 ton Hpu 96  
**Importance:** High

---

**From:** Rehan Hussain / Senior Manager Operations & Maintenance  
**Sent:** Wednesday, May 19, 2021 1:02 PM  
**To:** Qambar Zaidi / Senior Executive Purchase <qzaidi@iba.edu.pk>  
**Cc:** Syed Fahad Jawed / Head of Procurement <sjawed@iba.edu.pk>; Muhammad Hanif / Senior Executive (Purchase) <mhanif@iba.edu.pk>; Syed Muhammad Wajeesh Zaidi / Acting Head of ICT <smwzaidi@iba.edu.pk>  
**Subject:** RE: haier 8 ton Hpu 96  
**Importance:** High

Dear Qambar

Please note that for HPU-96CT03 working temp range of 10 – 53 degree Celsius is in accordance with class T3.

However,  
EER – Required by user is 3 or greater than 3.  
EER- offered is 2.67

Please take consent of the user – ICT, as discussed with user these requirements are based on vendor recommendation and some audit observations.

Regards  
Rehan