

Design, Supply, Installation, Testing & Commissioning of 200kWp Solar Roof Mounted Grid Tied PV System at IBA Karachi Boys Hostel University Enclave Karachi

MINUTES OF MEETING

Subject: Boys Hostel Solar System Pre-Bid Meeting

Meeting No. :

01

Client: IBA-KHI

Dated: February 01, 2024

Time: 11 45 Hrs.

Venue: Boys Hostel, IBA-Karachi.

Participants:

IBA's Representatives
<ul style="list-style-type: none">Syed Fahad Jawed (Associate Registrar Resource Optimization)Muhammad Naseem-ul-Haque (Senior Manager Projects)
<ul style="list-style-type: none">Hassan Ilyas (Assistant Electrical Engineer)Syed Asher Hussain (Assistant Civil Engineer)

S.No.	Company Name	Name Contractor/ Representative
1	Hexahedron Engineering	M. Riyan
2	Wateen Energy	Abdur Rehman
3	Osaka Lighting	Moez Iqbal Jaffery
4	Feroze Power	Rehmat/Hammad
5	Sunthesis	Sajjad Sher
6	EJ Solar	M.Umer Khan
7	ALF	Javed Iqbal
8	Supertek	Saqib Jamil
9	Maxes	Hassan Khan
10	Tricom Power	Moin/Ednan
11	Beacon Energy	M.Ammar Khan
12	Nizam Energy	Muneeb mujahid/M.Izhan

Deliberations

- 1) In case of Joint Venture (JV), bidder must submit JV agreement as per PEC guidelines.
- 2) In case of any deviation from bidding document supplied, use deviation form clearly indicating the deviation proposed, any kind of change desired in the bidding document/BOQ/specification.
- 3) Cross cutting/overwriting in BOQ/bidding document will not be considered as conditional bid that may lead to disqualification to proceed further in the bidding.
- 4) Bidders must fulfill all mandatory requirements, and if failure to any required information the bidder will be deemed disqualified to proceed further in the bidding.
- 5) In case of litigation, if there is any, it is mandatory for the bidder to provide the details of case/cases.
- 6) In net metering, IBA will bear the amount payable to K-Electric/NEPRA against the challan.
- 7) Facilitation & load inspection charges etc. during net metering shall be included in tendered item rates.
- 8) Last date of bid submission: February 07,2024 from 9:00 A.M to 3:00 PM, after 3:00 PM no bid will be accepted.
- 9) Working hours at IBA 08:00A.M to 5:30 P.M from Monday to Friday, in case of any bidder want to do site visit in holidays before bid submission, prior information on the following emails should be sent:
nmalik@iba.edu.pk
hilyas@iba.edu.pk
- 10) Any query related to tender must be done in writing on the following address while mentioning the tender number
tenders@iba.edu.pk
- 11) Operation & Maintenance time will start after submission of commissioning document.
- 12) Structure design should be semi elevated (Maximum height not more than 6feet) and tilt angle should be optimized as per design.
- 13) Mess area inverter mounting is to be installed inside the corridor, incase inverter mounting outside of the corridor, bidder must install Fiber shed and the cost of the shed shall be deemed to have been included in tendered rates.

Minutes Recorded By:

Hassan Ilyas, IBA