

Minutes of Meeting

A pre bid meeting was held on 3rd July 2026 at Project Department IBA Main Campus regarding the Procurement of “ Providing, Installation, Testing & Commissioning of Fire Hydrant System at IBA main Campus Karachi Tender No CW /30/25-26 at 11.00 AM. The Following two bidders attended the Prebid meeting.

1. M/S Ice Berg Industries
2. M/S Saif Fire Engineering.

Following are the deliberations of the Meeting:

1. Senior Manager Contract briefed regarding the scope of work and the following were clarified :
 - a) The Time of Completion of Job is 180 Working days after one week from issuance of LOA.
 - b) The Type of Fire Fighting Pump is Vertical Turbine type, 500 GPM with electrical driven motor and Jockey along with Controllers UL /FM listed Confirming to NFPA 20 latest edition.
 - c) The pump ,controllers and all fittings should be brand new and no refurbished component shall be accepted.
 - d) The clear depth of under ground tank is 10 ft and clear height of the pump room is 11ft.
2. The senior Manger briefed the meeting regarding Payment as mentioned in bidding data.
3. After Prebid meeting a joint site inspection was made.