

8. Bill of Quantity

Provide & Supply of UPS

Description	Specification	Quoted Model	Quoted Brand	Qty	Rate	Amount
Capacity	10 KVA	U-010R11H	ATTOM	3	484,300	1,452,900
Input	Single Phase					
	Voltage: 110-300 VAC					
	Power Factor: ≥ 0.99 Frequency: 46-54Hz or 56-64 Hz					
Output	Voltage: 208/220/230/240 Vac Power Factor: 1 Frequency: 50/60 Hz $\pm 1\%$ Current Crest					
Battery	Battery Voltage: 240Vdc Charging Current -A: 4A Max					
Protection	Full Protection of Under/Over Voltage					
Protection Phase	Spike/Surge Suppression Overload, Short Circuit					
Communication & Management	Interface Port: DB-9-RS-232, RJ-45 10/100 Base Multi-Function LCD Status and Control Console Auditable and Visible Alarms Emergency Power Off (EPO) SNMP					
Efficiency	AC Mode: 94% Battery Mode: 93%					
Warranty	1 Years Comprehensive Onsite Warranty in Islamabad, Lahore, and					
Brand	Vertiv / APC / Equivalent					
Total						1,452,900
Tax (if Applicable)					17%	246,993
Grand Total						1,699,893

Total Amount Rupees (in words) One Million Six Hundred Ninety-Nine Thousand Eight Hundred Ninety-Three Only

[Signature]
 MEMBER
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI

[Signature]
 CHAIRPERSON
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI



Stamp & Signature

[Signature]
 MEMBER
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI

[Signature]
 MEMBER
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI

[Signature]
 MEMBER (EXTERNAL)
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI

Page 12 of 17
[Signature]
 MEMBER
 CENTRAL PURCHASE COMMITTEE
 INSTITUTE OF BUSINESS ADMINISTRATION
 KARACHI